

AMENDMENT OF SOLICITATION

1. AMENDMENT/MODIFICATION NO. 0002	2. EFFECTIVE DATE APR 01, 2004	
3. ISSUED BY DEPARTMENT OF THE ARMY, BALTIMORE DISTRICT CORPS OF ENGINEERS P.O. BOX 1715 BALTIMORE, MARYLAND 21203-1715 CODE: _____		
4. NAME AND ADDRESS OF CONTRACTOR (Name, street, county, State and ZIP Code)	4A. AMENDMENT OF SOLICITATION NO. W912DR-04-B-0009 <hr/> 4B. DATED (SEE ITEM 5) MAR 15, 2004	
5. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ____ is extended, X is not extended. BID OPENING DATE : 2:00 PM, Local Time APR 15, 2004 Others must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 4 and 8, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of the amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.		
6. ACCOUNTING AND APPROPRIATION DATA (If required) LITTLE FALLS PUMPING STATION ELECTRICAL IMPROVEMENTS, WASHINGTON AQUEDUCT, WASHINGTON, D.C.		
7. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) <u>SPECIFICATIONS:</u> (1) <u>Section 01000, Paragraph 1.2.2:</u> Delete this paragraph in its entirety. (2) <u>Section 01320, Paragraph 3.3.2.6:</u> Delete this paragraph in its entirety. (3) <u>Section 01320, Paragraph 3.3.2.7:</u> Delete this paragraph in its entirety. (4) <u>Section 01320, Paragraph 3.3.2.9:</u> Delete this paragraph in its entirety. (5) <u>Section 01320, Paragraph 3.3.2.10:</u> Delete this paragraph in its entirety. (6) <u>Section 01320, Paragraph 3.3.2.11:</u> Delete this paragraph in its entirety. (7) <u>Section 01451, Paragraph 3.4.3:</u> Revise the fourth sentence of this paragraph to read: "The CQC System Manager may be assigned other duties." Except as provided herein, all terms and conditions of the document referenced in Item 4A, as heretofore changed, remains unchanged and in full force.		
8. NAME AND TITLE OF SIGNER (Type or print)	9. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	10. DATE SIGNED

(8) Section 16449, Paragraph 2.4.2 Construction, BID OPTION 2: Immediately at the beginning of the first paragraph insert the following sentence: "In lieu of refurbishing, repainting, testing and certifying the existing switchgear units, the Contractor shall provide new 350 MVA switchgear enclosures and demolish the existing switchgear enclosures, as specified in this Section and shown on the drawings.

(9) Section 16449, Paragraph 2.4.2 Construction, BID OPTION 2: Add the following sentences to the end of first paragraph: "In lieu of 26-inch wide one-high switchgear sections, the Government may consider standard 36-inch wide, one-high and/or two-high switchgear sections, with the conditions that all consequent modifications shall be provided at no additional cost to the Government, including but not limited to additional conduits, cables, wires, fittings, boxes, supports and core drillings of steel reinforced concrete floors, and that the new switchgear assemblies shall fit within the footprints of the existing switchgears. The Government reserves the right to reject any or all proposals for 36-inch wide switchgear sections."

(10) Section 16449, Paragraph 2.4.3 Bus, BID OPTION 2: Immediately at the beginning of the first paragraph insert the following sentence: "In lieu of designing, testing, manufacturing, on-site installation of 350 MVA bus bracing kits with analysis, design verification and certification of interrupting rating, the Contractor shall provide new 350 MVA busses and bus bracings, and demolish the existing switchgear busses and bus bracings, as specified in this Section and shown on the drawings.

(11) Section 16449, Paragraph 2.4.5 Circuit Breakers, second paragraph: Make the following changes:

(a) In the first sentence after "sulfurhexafluoride (SF6)" add "or vacuum".

(b) In the second sentence after "SF6" add "or vacuum".

(c) Add the following sentences to the end of this paragraph: "For both BASE BID and BID OPTION 2, new 5 kV 350 MVA SF6 or vacuum circuit breakers shall fit in 26-inch wide switchgear sections. For BID OPTION 2 only, the Government may consider new 5 kV 350 MVA SF6 or vacuum circuit breakers to fit in new 36-inch wide switchgear sections, one-high or two-high arrangement, provided all conditions specified in this Section are met."