



AMENDMENT OF SOLICITATION

1. AMENDMENT/MODIFICATION NO. 0003	2. EFFECTIVE DATE AUG 25, 2003	
3. ISSUED BY DEPARTMENT OF THE ARMY, BALTIMORE DISTRICT CORPS OF ENGINEERS P.O. BOX 1715 BALTIMORE, MARYLAND 21203-1715 CODE: _____		
4. NAME AND ADDRESS OF CONTRACTOR (Name, street, county, State and ZIP Code)	4A. AMENDMENT OF SOLICITATION NO. W912DR-04-B-0018 4B. DATED (SEE ITEM 5) AUG 02, 2004	
5. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers ____ is extended, X is not extended. BID OPENING 2:00 PM, Local Time SEP 02, 2004 Others must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 4 and 8, and returning <u>1</u> copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of the amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.		
6. ACCOUNTING AND APPROPRIATION DATA (If required) GATED SPILLWAY ELECTRICAL AND CONTROL UPGRADE, RAYSTOWN LAKE, PA		
7. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) <u>SPECIFICATIONS:</u> (1) <u>Section 01010 Page 3, Paragraph 1.1.9 and 1.1.10:</u> Delete these paragraphs. (2) <u>Section 01010 Pages 9-13, Paragraph 1.6 through 1.6.11:</u> Delete these paragraphs and substitute therefor the following: "1.6 SUBMITTALS: See Section 01330." (3) <u>Section 16410 Page 4 Paragraph 2.1e:</u> Change "Poles: Three switched and solid neutral." to "Poles Four switched". <u>DRAWINGS:</u> (4) <u>Plate 7:</u> Add to Dehumidifier with condenser note #2, "and 56.2 degrees F DB /56.0 degrees WB leaving air temperature." Add in accordance with sketch SK-4, dated August 24, 2004. Except as provided herein, all terms and conditions of the document referenced in Item 4A, as heretofore changed, remains unchanged and in full force.		
8. NAME AND TITLE OF SIGNER (Type or print)	9. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)	10. DATE SIGNED



SECT
MAIN



SCALE:

CONDENSER FAN(S)						REMARKS
FLA	HP	V/PH/HZ	AIR FLOW (CFM)	ESP (IN)		
1.0	0.5	480/3/60	1600	0.25	—	

SECTION AND HUMIDIFIER
RE, AND 56.2°F DB/ 56.0°F WB LEAVING AIR TEMPERATURE.



GATED SPILLWAY UPGRADE – RAYSTOWN

SK-4

PLATE 7

AUGUST 24, 2004

EAC, P.C.

9004-B CROWNWOOD COURT, BURKE, VA 22015

TEL. (703) 978-0923